

Building Code	Common Building Name	Fully Captured*	Total Usage (GJ)	Total Usage (kWh)	Carbon (Kg CO2-e)	Energy Density (MJ/m2) **	History Average Deviation ***
AA.AA01	40-42 Melville St (Podium & Biscuit Works)		6,679	1,855,333	315,407	844	49%
AA.GY01	exMcCanns		50	13,863	2,357	35	100%
AA.GY02	Goodyear site (Argyle St)		95	26,486	4,503	198	100%
AC.FH02	Fountainside Accommodation		1,642	391,166	78,554	835	37%
AF.AF02	103 Melville St (exK&D)		760	211,249	35,912	741	36%
AH.AH01	KPMG/MyState		248	68,760	11,689	142	100%
BB.BB01	Fire Training Building	Yes	335	74,783	16,682	943	-23%
BH.RC01	North West Rural Clinical School	Yes	607	168,723	28,683	541	-4%
BI	Bisdee Tier	Yes	158	43,840	7,453	503	45%
BP.BP11	Seamanship Centre	Yes	1,160	322,136	54,763	554	10%
CA.CA01	Centre for the Arts	Yes	6,871	1,037,277	337,978	571	18%
CD.CD01	Ceduna Building	Yes	195	54,069	9,192	0	-13%
DM.DM02	Electrical Engineering	No	873	141,908	42,799	1,039	9%
DM.DM09	Philip Smith Centre		5	1,455	247	5	-1569%
ER.ER03	Dairy Milking Complex	Yes	680	189,010	32,132	0	34%
ER.ER22	Offices-Elliott Research Station	Yes	39	10,800	1,836	0	-411%
FS.FS10	Offices (Power exc irr pumps)	Yes	95	26,499	4,505	0	-12%
HD.HD01	The Hedberg		5,989	1,663,610	282,814	544	37%
HD.HD03	Campbell St Accommodation (Theatre Royal Hotel)		21	5,912	1,005	0	-550%
IR.IR01	Stone Building and Annexe	Yes	1,880	512,602	88,907	318	-40%
IR.IR03	Workshop and Levee Studio	Yes	1,730	442,442	82,273	409	-24%
IR.IR07	Inveresk Apartments	Yes	1,345	373,749	63,537	385	-7%
IR.IR08	Railway Cottage		103	28,696	4,878	0	13%
KA.KA01	Katherine (CDU)		198	54,896	29,644	0	26%
LA.GE19	19 George Street		47	13,086	2,225	0	66%
LA.LA01	8 Palmers Rd, Latrobe Accom		77	21,379	3,634	286	-21%
LA.MR20	20 Moriarity Road		25	6,832	1,161	0	44%
ML.ML01	Melville Street Apartments	Yes	8,169	1,485,406	397,917	579	21%

Building Code	Common Building Name	Fully Captured*	Total Usage (GJ)	Total Usage (kWh)	Carbon (Kg CO2-e)	Energy Density (MJ/m2) **	History Average Deviation ***
ML.ML04	79-83 Melville St (exForestry Building)		339	94,174	16,010	0	-14%
MP.MP01	Mt. Pleasant Observatory	Yes	327	90,950	15,462	475	-165%
MR	Atrium Apartments, Cradle Coast Campus	Yes	733	203,731	34,634	639	23%
MR.CC	Cradle Coast Campus (excluding apartments)	Yes	1,278	355,091	60,365	294	-119%
MS.MS01	Medical Science 1	Yes	9,485	1,839,216	460,250	1,408	-36%
MS.MS02	Medical Science 2	Yes	11,780	1,681,031	580,942	1,759	22%
NH.AE31	NRAS Block D	Yes	612	170,056	28,910	477	5%
NH.AE32	NRAS Block C	Yes	805	223,636	38,018	598	19%
NH.AE34	NRAS Block B	Yes	476	132,318	22,494	540	16%
NH.AE35	NRAS Block A	Yes	404	112,174	19,070	501	0%
NH.AF35	NRAS Block Laundry	Yes	123	34,138	5,803	1,704	10%
NH.AG30	Cavitation Research Laboratory	Yes	629	174,634	29,688	933	6%
NH.AG33	Residence Block 8	Yes	196	54,500	9,265	361	-66%
NH.AG34	Residence Block 9	Yes	328	90,985	15,467	600	-25%
NH.AH25	Building T43 - Clubrooms		197	54,840	9,323	916	43%
NH.AH36	Residence Block 10	Yes	831	230,720	39,222	1,154	4%
NH.AI31	Model Test Basin	Yes	287	79,595	13,531	399	-12%
NH.AI33	Residence Block 2, 3 & 4	Yes	810	225,004	38,251	875	16%
NH.AJ21	Building T40B	Yes	113	31,500	5,355	5,662	50%
NH.AJ31	AUV Lab	Yes	58	16,241	2,761	187	6%
NH.AJ35	Residence Block 7	Yes	162	45,043	7,657	464	-44%
NH.AK34	Residence Block 5 & 6	Yes	505	140,215	23,837	817	-5%
NH.AL33	Residence Office 1 & 2 (inc Laundry)	Yes	166	46,162	7,848	1,094	-8%
NH.AM32	Survival Centre	Yes	1,807	501,873	85,318	1,360	6%
NH.AN21	Building T30-AFRDI		911	252,960	43,003	846	10%
NH.AN28	exCav Building (Labs)		105	29,105	4,948	211	-7%
NH.AO10	Childcare Centre	Yes	327	90,825	15,440	579	9%
NH.AO14	Childcare Cottage	Yes	38	10,652	1,811	286	55%
NH.AO16	Building T1,T5,T18,T7		73	20,180	3,431	144	96%
NH.AO24	Building S	Yes	2,516	698,955	118,822	953	21%
NH.AO37	Master Of Residence	Yes	79	22,048	3,748	761	-50%

Building Code	Common Building Name	Fully Captured*	Total Usage (GJ)	Total Usage (kWh)	Carbon (Kg CO2-e)	Energy Density (MJ/m2) **	History Average Deviation ***
NH.AP24	Building T26	Yes	200	55,662	9,463	751	6%
NH.AP26	Electro Technology Laboratory	Yes	202	56,182	9,551	374	-70%
NH.AP30	AMC Communal Centre	Yes	1,626	378,401	80,316	1,343	-10%
NH.AP40	Riverside Cottage		129	35,895	6,102	998	86%
NH.AQ34	Newnham Hall	Yes	488	135,521	23,039	1,288	19%
NH.AR26	Thermo Dynamics	Yes	133	26,318	7,184	372	-6%
NH.AR29	Connell Building	Yes	885	245,792	41,785	769	14%
NH.AR30	Simulator	Yes	1,190	330,504	56,186	1,296	6%
NH.AR32	Norfolk Hall	Yes	886	245,977	41,816	1,122	10%
NH.AS17	Building T9-University Sports Centre	Yes	428	118,999	20,230	278	-14%
NH.AS23	Building V-Computing	Yes	757	144,681	36,745	503	-57%
NH.AT17	Building T8-AMS Office	Yes	214	59,580	10,129	579	26%
NH.AT19	Building R-Aquaculture	Yes	806	223,800	38,046	475	-70%
NH.AU10	Building Q2 Leprena S	Yes	135	37,613	6,394	240	-289%
NH.AU23	Building P Kerslake Hall	No	4,159	119,609	212,435	5,731	85%
NH.AV25	Building H Kerslake Hall	Yes	898	249,445	42,406	1,124	-16%
NH.AV29	Swanson Building	Yes	2,652	736,678	125,235	458	-7%
NH.AW08	Building-Q3 & Q4 Leprena W	Yes	102	28,421	4,832	180	-453%
NH.AW10	Building-Q5 Leprena Community Centre	Yes	17	4,586	780	219	-160%
NH.AW12	Building-Q1 Leprena Q	Yes	611	169,716	28,852	426	-108%
NH.AW22	Building Z-TUU Building	Yes	727	151,131	35,107	651	-29%
NH.AX23	Building O-Psychology	Yes	149	41,520	7,058	533	-16%
NH.AX24	Building Y-Student Centre	No	6,186	88,855	317,369	5,418	85%
NH.AX26	Building J-Hospital Simulation Centre	Yes	994	155,510	48,805	578	5%
NH.AY23	Building N-Nursing	No	976	162,990	47,775	1,003	26%
NH.AY27	Building E-Engineering	Yes	403	111,942	19,030	385	-4%
NH.AZ22	Building G-Human Movement	Yes	13	3,528	600	5	-3325%
NH.AZ25	Building M-Nursing	No	848	108,900	42,033	744	26%
NH.BA25	Building C-Human Life Sciences	No	1,626	222,800	80,357	789	-16%
NH.BA27	Building D-Commerce/Law	No	767	81,530	38,254	648	24%
NH.BB22	Building B-Administration & Library	No	2,774	332,359	137,816	538	34%

Building Code	Common Building Name	Fully Captured*	Total Usage (GJ)	Total Usage (kWh)	Carbon (Kg CO2-e)	Energy Density (MJ/m2) **	History Average Deviation ***
NH.BB24	Building F-English Language Centre	No	208	18,781	10,404	593	30%
NH.BE21	Building X-Ferrall Centre	No	830	121,380	40,894	701	-3%
NH.BF24	Building A	No	6,765	1,081,239	331,817	916	22%
SA.SA02	IMAS-Salamanca	Yes	10,490	1,438,121	518,269	1,946	24%
SA.SA03	Media School, Salamanca Place	Yes	223	61,900	10,523	272	65%
SB.AC06	301 Sandy Bay Rd	Yes	241	67,024	11,394	536	9%
SB.AD07	6 Grace St	Yes	65	18,110	3,079	323	-95%
SB.AG10	Child Care	Yes	218	60,432	10,273	436	-9%
SB.AH10	Community Health Clinic	Yes	23	6,334	1,077	427	-35%
SB.AI08	Rugby Pavilion	Yes	5	1,403	239	36	-942%
SB.AI11	Unigym	Yes	927	257,482	43,772	450	-3%
SB.AJ10	After School Care	Yes	43	12,048	2,048	238	-79%
SB.AJ13	exIMAS	Yes	667	185,375	31,514	586	-26%
SB.AK12	Cricket Pavilion	Yes	35	9,744	1,657	221	5%
SB.AL14	Law	No	1,736	482,325	81,995	511	-10%
SB.AO20	University Club	Yes	294	81,533	13,861	524	-20%
SB.AP16	Engineering	No	2,934	272,585	146,937	860	13%
SB.AQ18	Engineering Workshop	No	1,385	164,945	68,806	575	42%
SB.AR15	Centenary Building	Yes	2,483	689,832	117,271	582	-8%
SB.AR19	Chemistry	No	13,818	1,856,830	683,239	2,166	29%
SB.AR20	Pharmacy	Yes	394	109,521	18,619	485	-29%
SB.AS13	Geography-Geology & CODES	No	3,693	721,315	179,095	751	5%
SB.AS25	TUU-Student Union	Yes	1,057	293,631	49,917	226	-64%
SB.AT15	Mathematics	No	520	66,880	25,759	897	40%
SB.AU14	Physics	No	2,396	417,902	116,961	653	12%
SB.AU19	Library Morris Miller	No	3,323	608,743	161,775	604	-3%
SB.AU28	Research House	Yes	98	27,361	4,651	338	-4%
SB.AW20	Studio Theatre	Yes	199	55,187	9,382	315	-8%
SB.AW21	Administration	Yes	820	227,704	38,710	537	10%
SB.AW31	Hytten Hall	Yes	772	214,404	36,449	231	-65%
SB.AX14	Psychology Research Centre	Yes	326	90,579	15,398	381	-39%

Building Code	Common Building Name	Fully Captured*	Total Usage (GJ)	Total Usage (kWh)	Carbon (Kg CO2-e)	Energy Density (MJ/m2) **	History Average Deviation ***
SB.AX16	Arts Lecture Theatre		477	132,581	22,539	1,125	29%
SB.AX17	Social Sciences	No	2,054	257,832	101,849	502	-6%
SB.AX19	University Centre	No	1,244	228,668	60,568	723	-2%
SB.AX24	Herbarium	Yes	136	37,798	6,426	298	-8%
SB.AX33	Commerce	Yes	865	240,260	40,844	356	-12%
SB.AZ16	Humanities	Yes	1,725	322,512	83,897	872	26%
SB.BA22	Life Sciences	Yes	7,949	1,605,761	384,713	1,096	15%
SB.BB26	Plant / Ag Science Glasshouse		3,538	982,669	167,054	2,559	1%
SB.BB36	University Apartments Building 5, 6, 7, 8	Yes	668	185,418	31,521	167	-80%
SB.BB40	Uni Aparts 1,2, Laundry & AS/ISD offices		1,064	290,559	50,319	876	-7%
SB.BC24	Life Sciences Annexe - TIA	Yes	1,007	83,927	50,601	1,589	42%
SB.BD39	St John Fisher College	No	2,036	425,816	94,430	737	-33%
SB.BE20	Corporate Services Building	Yes	8,630	2,397,180	407,521	4,904	5%
SB.BE26	Old Medical Sciences	Yes	2,836	462,943	138,942	1,031	14%
SB.BF21	Electrode Boiler House		2,188	607,744	103,316	0	33%
SB.BF31	CSIRO Forestry	Yes	1,033	287,079	48,803	3,375	-33%
SB.BI21	Steps Building	Yes	216	59,917	10,186	593	13%
SB.BN25	Horticultural Research Centre	Yes	2,776	523,986	134,926	2,694	6%
SB.CC	Christ College Total	No	3,163	700,361	110,014	898	-15%
SB.CH60	Olinda Grove Clubrooms	Yes	40	10,997	1,650	201	-28%
TT	IMAS Tarooma (whole site)	Yes	15,677	4,354,744	653,212	4,383	10%
UF.UF01	University Farmhouse	Yes	11	3,063	459	89	-4959%
UF.UF03	Small Animal Facility (Uni Farm Facility)	Yes	1,766	490,584	73,588	9,055	8%
WP.WP01	Makers Workshop	Yes	218	39,311	9,820	203	-474%
WP.WP02	Field Building (exDomestic Arts)	Yes	1,162	322,790	48,418	319	93%
WP.WP03	Student Apartments	Yes	607	168,573	25,286	405	18%

* 'Fully captured' denotes if a building's energy consumption has been fully captured or not, as some are served by unmetered supplies or by central heating systems

** Energy density is based on the usable floor area (UFA) of the building.

*** N/A has been used where no historical values are available or sufficient spatial data.

NOTE: The 'Energy Density' and 'History Average Deviation' columns use a graded colour scale where dark green indicates best performance and red indicates worst performance.

